



**AIR EMISSION PERMIT NO. 12300053- 001**

**IS ISSUED TO**

**METROPOLITAN COUNCIL**

**METROPOLITAN WASTEWATER TREATMENT PLANT**

**2400 Childs Road**

**St. Paul, Ramsey County, Minnesota 55106**

The emission units, control equipment and emission stacks at the stationary source authorized in this permit are as described in the following permit application(s):

Permit Type	Application Date
Total Facility Operating Permit	December 13, 1995


This permit authorizes the Permittee to operate the stationary source at the address listed above unless otherwise noted in Table A. The Permittee must comply with all the conditions of the permit. Any changes or modifications to the stationary source must be performed in compliance with Minn. R. 7007.1150 to 7007.1500. Terms used in the permit are as defined in the state air pollution control rules unless the term is explicitly defined in the permit.

**Permit Type:** Federal; Part 70/Major for NSR

**Issue Date:** March 13, 2001

**Expiration:** March 13, 2006

All Title I Conditions do not expire.

  
Richard J. Sandberg, Manager  
Major Facilities Section  
Metro District

for Karen A. Studders, Commissioner  
Minnesota Pollution Control Agency

## Excerpts :

page 12 :

Performance Test: due by the end of each calendar year following Permit Issuance to measure PM, PM10, and Opacity emissions on any two incinerators, EU008-013, as selected by the Permittee and specified in the test plan and approved by the MPCA.

Note :: MPCA = Minnesota Pollution Control Agency

page 13 :

Recordkeeping: The Permittee shall record in the operating log the time of emergency relief stack damper opening and closing when sludge is being incinerated.

Recordkeeping: The Permittee shall record the average sludge feed rate during all periods of incinerator operation for each incinerator, in wet tons per hour.

page 14 :

due 30 days after end of each calendar half-year starting 01/01/2001 the Permittee shall submit a Semiannual Deviation Report which contains a record of the average oxygen content in the incinerator exhaust gas for each period of 1-hour duration or more that the oxygen content of the incinerator exhaust gas exceeds the average oxygen content measured during the most recent performance test by more than 3 percent.

due 30 days after end of each calendar half-year following Permit Issuance (The report shall contain the results of monthly mercury sampling of the mixed sludge charged to the incinerators).